

Date Prepared 05/2001
Revised 3/15/05, 2/28/07, 9/17/08
P Watt
Prepared By Carla McGreevy

BMP Physical Plant #8

TITLE: Aboveground Tank Labeling

Regulatory Citation: 6 NYCRR Part 613.5 (a)

Applicability: All aboveground tanks must be labeled:

Purpose: To identify the tank and list its capacity to prevent overfilling.

**Person or
Department Responsible:** Executive Mgr Physical Plant/Stationery Engineers

Schedule: Not Applicable.

Procedures: The tanks must be labeled with the following information:

Registration Number	Tank Contents	Working/Design Capacity (Gallons)
FZ 2	#2 Fuel Oil	495/550
WIL1	#2 Fuel Oil	180
HG2	Diesel winter mix	275/300
GEN 2	diesel	320/400
COG 1	Used oil	385/310
LSB 1	Gasoline	1,800/2,000
LSB 2	Diesel	900/1,000

In addition each of the tanks must be equipped with a level gauge and the fill port must be labeled as follows:

FZ2 and WIL-1 fill port must be labeled with a green hexagon.
LSB-2, HG-2 and GEN 2 fill port must be labeled with a yellow hexagon.
COG 1 fill port must say used oil
LSB-1 must be labeled with a white cross

Record keeping: Not Applicable.

Record Location: Not Applicable.

Contact: Director of Environmental, Health and Safety (629-7163)
Exec Mgr of Physical Plant (629-7427)
Assistant to Exec Mgr 629-7361

HVCC-BMP-PhysicalPlant#8-ASTLabeling